



CO2 emissions permit for Statoil's combined heat and power plant at

Letter | Date: 12/10/2006 | [Ministry of Climate and Environment](#)

(<http://www.regjeringen.no/en/dep/kld/id668/>)

Originally published by: Ministry of the Environment

CO2 emissions permit for Statoil's combined heat and power plant at Mongstad:

The CO2 emissions permit for Statoil's combined heat and power plant at Mongstad is pursuant to the Act of 13 March 1981 concerning protection against pollution and concerning waste (the Pollution Control Act) no. 6 § 11, cf. § 16. The permit is issued on the basis of information supplied in the application dated 30 June 2005, plus information emerging during assessment of the application.

The permit applies to energy production in the cogeneration plant with installed gas-fired effect of approx. 800 MW (producing approx. 350 MW heat and approx. 280 MW electric power).

Conditions

1. Statoil is issued the permit as sought for CO2 emissions from the proposed cogeneration plant at Mongstad. Until a full-scale CO2 treatment system is in place, the following emission limits apply to the cogeneration plant: 1.3 mill. tonnes CO2 per year.
2. Full-scale management of CO2 from the cogeneration plant must be established by the end of 2014.